

MEMORANDUM

DEPARTMENT OF ENVIRONMENTAL QUALITY Piedmont Regional Office

4949-A Cox Road

Glen Allen, VA 23060-6295

804/527-5020

SUBJECT: Norview Marina, Middlesex Co. (VA#0087611)

TO: File

FROM: Meredith R. Williams

DATE: May 1, 2008

COPIES: Mr. Douglas Respress, DEQ-PRO (R/R file), OWCP

An unannounced technical inspection was conducted on April 29, 2008 (1117-1135 hrs) by Inspectors, Meredith Williams and Heather Horne to determine the current on site status. Mr. Douglas Respress, General Manager, accompanied us during the inspection. The VPDES Permit has been issued for a wastewater treatment plant which has not been constructed. The new owner of this facility may possibly be developing the site in the future. The site is currently using an on site subsurface disposal system (i.e, septic tank and sand filter). There was no evidence of problems on the drainfield site. Used oils from the repair shop are removed by a contractor.



Field where plant will be built



Vicinity of current drainfield



Septic tanks – 2 @ 2500 gals



Pump tank (to drainfield)



Vacuum flush tank